

TYPICAL TEST DATA
LV Dry Type Transformer



MODEL #: **9T33A2670**

Underwriters' Laboratories Inc. Listed

RATINGS

KVA	15	Conductor	AL
Frequency (Hz)	60	Phase	1
Primary Voltage	480/240 +2/-4 X 2.5% (S)	Secondary Voltage	240/120
Current Line Primary (A)	31.25	Current Line Secondary (A)	62.50
Frame	YX171	Insulation System (°C)	220C
K Factor	1	Efficiency level	DoE 2016(10CFR 431)
Temp. Rise (°C)	150	Average Sound Level (dB)	45

LOSS DATA @ 100% LOAD

Core Loss or No Load Loss @ 100% voltage (Watts)	71.2
Impedance Loss or Coil Loss @ Rise + 20 °C reference (Watts)	<u>524.7</u>
Total Loss @ Rise + 20 °C reference (Watts)	595.9

DIELECTRIC AND PRODUCTION TESTING

Induce Test @ Twice rated voltage 400 Hz per UL1561 and NEMA ST-20
Hipot Test for High Voltage winding to Low Voltage and Ground @ 4000 volts 60 Hz, 60 Sec
Hipot Test for Low Voltage winding to High Voltage and Ground @ 2500 volts 60 Hz, 60 Sec
Polarity additive in accordance with UL1561 and NEMA ST-20

EFFICIENCY:

DoE 2016(10CFR 431) Efficiency Level

<u>Load (%)</u>	<u>Efficiency (%)</u>
16	96.72
25	97.51
35	97.70
50	97.78
75	97.45
100	96.98

IMPEDANCE:

Impedance at reference temperature of Rise + 20 °C
(Calculated)

%R	3.5
%X	3.1
%Z	4.7
X/R Ratio	0.9

REGULATION:

Regulation at reference temperature of Rise + 20 °C (Calculated)

<u>Power Factor</u>	<u>Regulation (%)</u>
1	3.7
0.9	4.7
0.8	4.9

REFERENCE VALUES:

Inrush Current (Calculated)	t= 8.33ms
I _{max} (RMS)	≈ 40 A