

GENERAL ELECTRIC DRY TYPE TRANSFORMERS


NOTES:

- 1) ALL UNITS ARE UL LISTED AND ARE DESIGNED IN ACCORDANCE WITH ANSI C89.2 AND NEMA ST-20 STANDARDS.
- 2) TRANSFORMERS UTILIZE A UL RECOGNIZED 220'C INSULATION
 SYSTEM. THE TEMPERATURE RISE(S) FOR THE SPECIFIC kVA RATINGS
 REFERENCED IN THE TABLE BELOW ARE DETERMINED WHEN THE
 TRANSFORMER IS MOUNTED IN A STANDARD ENCLOSURE.
- 3) TRANSFORMERS ARE DESIGNED FOR FLOOR MOUNTING.
- 4) TRANSFORMERS ARE DRY TYPE, CLASS AA, WITH VENTILATED ENCLOSURES FOR INDOOR USE. OPTIONAL RAINSHIELD KITS ARE AVAILABLE TO ADAPT ALL SIZES FOR TYPE 3R OUTDOOR USE WITHOUT VOIDING THE WARRANTY.
- 5) APPLICABLE WHEN OPTIONAL RAINSHIELDS ARE INSTALLED. RAINSHIELDS ARE SHIPPED IN KITS FOR FIELD INSTALLATION.
- 6) CABLE ENTRANCE IS PERMITTED THROUGH THE LEFT SIDE, RIGHT SIDE AND/OR BOTTOM ENCLOSURE PANELS ONLY. CABLE ENTRANCE IS NOT PERMITTED THROUGH THE FRONT, REAR OR TOP PANELS.
- 7) 0.563" DIA HOLES ARE PROVIDED FOR CUSTOMER TERMINATION.
- 8) FOR LIFTING, OTHER THAN WITH A FORK TRUCK, REMOVE TOP COVER AND USE 1" DIAMETER HOLES IN THE TOP CORE CLAMPS.
- 9) PAINT COLOR IS ANSI #61 GRAY.
- 10) 6" MINIMUM CLEARANCE IS REQUIRED FROM ALL WALLS.





TYPICAL kVA RATINGS AND TEMPERATURE RISES						
	REI	F. kVA	AT	WEIGHT LBS. (APPROX.)	dB LEVEL	
COIL	150°C RISE	115°C RISE	80°C RISE			
COPPER	75	N/A	N/A	920	50	



OTV	COIL CONDUCTOR	kVA	TEMP RISE	VOL	TAPS	
QII.				PRIMARY	SECONDARY	IAFS

CUSTOMER		UNLESS OTHERWISE SPECIFIED ALL DIMENSIONS ARE IN INCHES
JOB NAME		THIRD ANGLE PROJECTION
LINE #		
DESIGNATION		
DRW NO.	303B431AAP074	SHEET 1 OF 1



GENERAL ELECTRIC COMPANY

GE Consumer & Industrial

OUTLINE DRAWING
HARMONIC MITIGATING VENTED UNIT
TP1, 3 PHASE

CATALOG NO. REV.