

AMP	POLE	WEIGHT LB(kg)	CENTER OF GRAVITY in(mm)		
			X	Y	Z
100-400 (ZBTSCT)	2,3	1245(565)	18.0(457)	36.0 (914)	18.5 (470)
	4	1450(658)	20.0(508)		

ZBTS(D)CT AMP	POLE	WEIGHT LB(kg)	CENTER OF GRAVITY in(mm)		
			X	Y	Z
600	3	1245(565)	18.0(457)	36.0 (914)	18.5 (470)
	4	1450(658)	20.0(508)		
800-1200	3	1400(635)	20.0(508)	36.0 (914)	18.5 (470)
	4	1670(757)	23.0(584)		

**NOTES:**

- ALL DIMENSIONS ARE FOR REFERENCE ONLY AND SHOWN IN INCHES (MILLIMETERS).
- BOLT ENCLOSURE FROM C-CHANNEL BASE (SEE DETAIL B) USING THE FOLLOWING SEISMIC CERTIFIED MOUNTING HARDWARE PER MOUNTING HOLE:  
(HARDWARE PROVIDED BY INSTALLER).
  - \* 1/2-13 GRADE 5 BOLT TORQUE TO 75 FT-LBS. (102 NEWTON METERS).
  - \* 1/2-13 STANDARD FLAT WASHER
  - \* 1/2 (13) HELICAL SPRING LOCK WASHER.
- CENTER OF GRAVITY DIMENSIONS ARE FOR REFERENCE ONLY.
- FOR WORKING CLEARANCE REFER TO NATIONAL AND LOCAL CODES AND STANDARDS.

SIGNATURES	DATE
MODEL GG	05/13/08
DETAIL	
CHECKED	
ENGRG	
MFG	
QUALITY	
ISSUED	
DRAWING FILE: 50c-1003.dwg	SIZE B
MODEL / ASSEMBLY FILE:	CAGE CODE
# CTQs	DWG NO
⊕ CRITICAL TO QUALITY CHARACTERISTIC	


**ABB**

**SEISMIC MOUNTING  
FOR NEMA-1 CABINET**

FIRST MADE FOR: ZBTS(D)(CT) 600-1200A & ZBTSCT 100-400A

**50C-1003**

SCALE: N/A SHEET 2 OF 2



**ABB PROPRIETARY AND CONFIDENTIAL INFORMATION**

The information contained in the document has to be kept strictly confidential. Any unauthorized use, reproduction, distribution or disclosure to third parties is strictly forbidden. ABB reserves all rights regarding intellectual Property Rights. Copyright 2018 ABB. All rights reserved

AutoCad Generated

