




Transformer




Catalog Number **9T10A1003** Type QL

45.0 KVA 60 HZ 3 PH 4.3 % IMP
40 C.AMB. 150 C.RISE 220 C.SYSTEM IS-15C

PRIMARY (H) 480 VOLTS (LINE-LINE)
SECONDARY (X) 208 VOLTS (LINE-LINE)
120 VOLTS (LINE-NEUTRAL)



COIL TAP ARRANGEMENT



JUMPER CONNECTION TAP	VOLTS
1	584
2	491
3	480
4	467
5	457
6	444
7	431

NET WGT
363 LB
164.7 Kg

73717
UV73A
NOS
110117

INSPECTION & FINAL TEST N744!



LISTED 7696

ENCLOSURE TYPE 2 (IP20). OR RAINPROOF TYPE 3R (IP22) WHEN PROVIDED SHIELD 9T18Y1072G06

BEFORE HANDLING, INSTALLING AND OPERATING, SEE INSTRUCTION 475A667AAP001 Outline:
ALUMINUM CONDUCTOR PRIMARY: 10 KV BIL SECONDARY: 10 KV BIL 303B111GEUVP73A

IN ACCORDANCE WITH NEC SECTION 450-9, ALLOW AT LEAST SIX INCHES CLEARANCE FOR VENTILATION. CHECK ADDITIONAL NEC AND LOCAL CODE

Assembled in Mexico


X3 H3 X2 H2 X1 H1 X0

Note: standard

X0
X3 H3 X2 H2 X1 H1



X0
X3 H3 X2 H2 X1 H1



GE Energy Industrial Solutions

NEMA CLASS AA DRY TYPE TRANSFORMER

Meets DOE 2016 efficiency