

TYPICAL TEST DATA

LV Dry Type Transformer



MODEL #: 9T10A1007G04

Underwriters' Laboratories Inc. Listed

RATINGS

KVA	225	Conductor	AL
Frequency (Hz)	60	Phase	3
Primary Voltage	480D +2, -4 (2.5% taps)	Secondary Voltage	208Y/120
Current Line Primary (A)	270.63	Current Line Secondary (A)	624.54
Frame	DY77A	Insulation System (°C)	220C
K Factor	1	Efficiency level	DoE 2016 (10CFR 431)
Temp. Rise (°C)	150	Average Sound Level (dB)	52

LOSS DATA @ 100% LOAD

Core Loss or No Load Loss @ 100% voltage (Watts)	375.3
Impedance Loss or Coil Loss @ Rise + 20 °C reference (Watts)	<u>5,108.4</u>
Total Loss @ Rise + 20 °C reference (Watts)	5,483.8

DIELECTRIC AND PRODUCTION TESTING

Induce Test @ Twice rated voltage 400 Hz per UL1561 and NEMA ST-20
 Hipot Test for High Voltage winding to Low Voltage and Ground @ 4000 volts 60 Hz, 60 Sec
 Hipot Test for Low Voltage winding to High Voltage and Ground @ 2500 volts 60 Hz, 60 Sec
 Polarity additive in accordance with UL1561 and NEMA ST-20

EFFICIENCY:

DoE 2016 (10CFR 431) Efficiency Level

<u>Load (%)</u>	<u>Efficiency (%)</u>
16	98.70
25	98.92
35	98.94
50	98.83
75	98.52
100	98.16

IMPEDANCE:

Impedance at reference temperature of Rise + 20 °C (Calculated)

%R	2.3
%X	4.9
%Z	5.4
X/R Ratio	2.1

REGULATION:

Regulation at reference temperature of Rise + 20 °C (Calculated)

<u>Power Factor</u>	<u>Regulation (%)</u>
1	2.4
0.9	4.6
0.8	5.2

REFERENCE VALUES:

Inrush Current (Calculated)	t= 8.33ms
I _{max} (RMS)	≈3624.72A