








Transformer



1M000000

| <p>Catalog Number 9T10C1002G61</p> <p>Type QL</p> <p>30.0 KVA 60 HZ 3 PH 2.2 % IMP</p> <p>40 C AMB. 80 C RISE 220 C SYSTEM IS-19C</p> <p><i>Note: Design is based on 45.00KVA & 115C Rise 3.4% Imp.</i></p> <p>PRIMARY (H) 480 VOLTS (LINE-LINE) SECONDARY (X) 208 VOLTS (LINE-LINE) 120 VOLTS (LINE-NEUTRAL)</p> |  | <p>JUMPER CONNECTION</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>TAP</th> <th>VOLTS</th> </tr> </thead> <tbody> <tr><td>1</td><td>502</td></tr> <tr><td>2</td><td>491</td></tr> <tr><td>3</td><td>480</td></tr> <tr><td>4</td><td>469</td></tr> <tr><td>5</td><td>455</td></tr> <tr><td>6</td><td>444</td></tr> <tr><td>7</td><td>433</td></tr> </tbody> </table> | TAP | VOLTS | 1 | 502 | 2 | 491 | 3 | 480 | 4 | 469 | 5 | 455 | 6 | 444 | 7 | 433 | <p>NET WGT 480 LB 217.7 Kg</p> <p>68371 UX73C NOG 032117</p> <p>INSPECTION & FINAL TEST N712!</p> |
|---|--|--|-----|-------|---|-----|---|-----|---|-----|---|-----|---|-----|---|-----|---|-----|--|
| TAP | VOLTS | | | | | | | | | | | | | | | | | | |
| 1 | 502 | | | | | | | | | | | | | | | | | | |
| 2 | 491 | | | | | | | | | | | | | | | | | | |
| 3 | 480 | | | | | | | | | | | | | | | | | | |
| 4 | 469 | | | | | | | | | | | | | | | | | | |
| 5 | 455 | | | | | | | | | | | | | | | | | | |
| 6 | 444 | | | | | | | | | | | | | | | | | | |
| 7 | 433 | | | | | | | | | | | | | | | | | | |
| <p>COIL TAP ARRANGEMENT</p> <div style="display: flex; justify-content: space-around;">    </div> | |  | | | | | | | | | | | | | | | | | |
| <p>ENCLOSURE TYPE 2 (IP20). OR RAINPROOF TYPE 3R (IP22) WHEN PROVIDED SHIELD 9T18Y1072G06</p> <p>BEFORE HANDLING, INSTALLING AND OPERATING, SEE INSTRUCTION 475A667AAP001 COPPER CONDUCTOR PRIMARY: 10 KV BIL SECONDARY: 10 KV BIL Outline: 303B111GEUXP73C</p> <p>IN ACCORDANCE WITH NEC SECTION 450-9, ALLOW AT LEAST SIX INCHES CLEARANCE FOR VENTILATION. CHECK ADDITIONAL NEC AND LOCAL CODE</p> <p>GE Energy Industrial Solutions NEMA CLASS AA DRY TYPE TRANSFORMER Meets DOE 2016 efficiency</p> | | <p>Assembled in Mexico</p> <p>X3 H3 X2 H2 X1 H1 -</p> <p>- - - - -</p> <p>Note: X0 at the top</p> | | | | | | | | | | | | | | | | | |

X3 H3 X2 H2 X1 H1



2M0000000