# Transformer

by ABB

*1M0000000*

**Catalog Number** **Type QL**

**9T10C1003G32**

**45.0 KVA** **60 HZ** **3 PH** **3.2 % IMP**

**40 C AMB.** **115 C RISE** **220 C SYSTEM** **IS-19C**

| JUMPER CONNECTION TAP | VOLTS |
|---|---|
| 1 | 502 |
| 2 | 491 |
| 3 | 480 |
| 4 | 469 |
| 5 | 455 |
| 6 | 444 |
| 7 | 433 |

PRIMARY (H) 480 VOLTS (LINE-LINE)
SECONDARY (X) 208 VOLTS (LINE-LINE)
120 VOLTS (LINE-NEUTRAL)




COIL TAP ARRANGEMENT



NET WGT
480 LB
217.7 Kg
89484
UX73C

INSPECTION & FINAL TEST
NOG
N137!
091021

Energy Verified
EV519886

LISTED 769G

ENCLOSURE TYPE 2 (IP20). OR RAINPROOF TYPE 3R (IP22) WHEN PROVIDED SHIELD 9T18Y1072G06

BEFORE HANDLING, INSTALLING AND OPERATING, SEE INSTRUCTION 475A667AAP001

COPPER CONDUCTOR PRIMARY: 10 KV BIL SECONDARY: 10 KV BIL

IN ACCORDANCE WITH NEC SECTION 450-9, ALLOW AT LEAST SIX INCHES CLEARANCE FOR VENTILATION. CHECK ADDITIONAL NEC AND LOCAL CODE

ASSEMBLED IN MEXICO

| X3 | H3 | X2 | H2 | X1 | H1 | - |
|---|---|---|---|---|---|---|
| - | - | - | - | - | - | |

Note: **X0 at the top**

Outline: 303B111GEUXP73C

NEMA CLASS AA DRY TYPE TRANSFORMER

Meets DOE 2016 efficiency

| X3 | H3 | X2 | H2 | X1 | H1 | - |
|---|---|---|---|---|---|---|
| - | - | - | - | - | - | |

*2M0000000*

| X3 | H3 | X2 | H2 | X1 | H1 | X0 |
|---|---|---|---|---|---|---|
| - | - | - | - | - | - | - |

*3M0000000*