# Transformer

by ABB

*1M0000000*

**Catalog Number** **Type QL**

**9T11A1023G03**

**45.0 KVA 60 HZ 3 PH 3.5 % IMP**

**40 C AMB. 150 C RISE 220 C SYSTEM IS-19C**

*Note: Design is based on 45.00KVA & 150C Rise 3.5% Imp.*

| JUMPER CONNECTION TAP | VOLTS |
|---|---|
| 1 | 505 |
| 2 | 492 |
| 3 | 480 |
| 4 | 469 |
| 5 | 456 |
| 6 | 443 |
| 7 | 433 |

PRIMARY (H) 480 VOLTS (LINE-LINE)
SECONDARY (X) 220 VOLTS (LINE-LINE)
127 VOLTS (LINE-NEUTRAL)

ELECTROSTATIC GROUND SHIELD IN EACH PHASE




COIL TAP ARRANGEMENT



NET WGT 444 LB 201.4 Kg 88729 UX73A

INSPECTION & FINAL TEST NOG N137! 091021

Energy Verified EV519886

LISTED 769G

ENCLOSURE TYPE 2 (IP20). OR RAINPROOF TYPE 3R (IP22) WHEN PROVIDED SHIELD 9T18Y1072G06

**SUITABLE FOR NONSINUSOIDAL CURRENT LOAD WITH K-FACTOR NOT TO EXCEED 13**

BEFORE HANDLING, INSTALLING AND OPERATING, SEE INSTRUCTION 475A667AAP001

ALUMINUM CONDUCTOR PRIMARY: 10 KV BIL SECONDARY: 10 KV BIL

IN ACCORDANCE WITH NEC SECTION 450-9, ALLOW AT LEAST SIX INCHES CLEARANCE FOR VENTILATION. CHECK ADDITIONAL NEC AND LOCAL CODE

ASSEMBLED IN MEXICO

| X3 | H3 | X2 | H2 | X1 | H1 | X0 |
|---|---|---|---|---|---|---|
| - | - | - | - | - | - | - |

Note: **standard**

Outline: 303B111GEUXP73A

NEMA CLASS AA DRY TYPE TRANSFORMER

Meets DOE 2016 efficiency

X0 H1 X1 H2 X2 H3 X3

*2M0000000*

X0 H1 X1 H2 X2 H3 X3

*3M0000000*