Transformer

by ABB

1M0000000

Catalog Number

9T33A2674

Type QL

75.0 KVA | 60 HZ | 1 PH | 6 % IMP

40 C AMB. | 150 C RISE | 220 C SYSTEM | IS-19C

PRIMARY LINES ON H1-H4				SECONDARY LINES ON X1-X4	
VOLTS	CONNECT	VOLTS	CONNECT	VOLTS	CONNECT
	H1-H3,H2-H4	432	7-8	120	X1-X3,X2-X4
216	7-8	442	6-7	240	X2-X3
230	5-6	460	5-6		
240	3-4	470	4-5	SECONDARY	
250	1-2	480	3-4	LINES ON X1-X2-X4	
		490	2-3	VOLTS	CONNECT
		500	1-2	120/240	X2-X3



COIL TAP ARRANGEMENT



NET WGT 600 LB 272.2 Kg 90125 YX174

NOG 091021 INSPECTION & FINAL TEST N137!

Energy Verified EV519886

Energy Verified EV23760

LISTED 769G

X4 - X2 - X1 - X3 -

H1 - H4 -

2M0000000

X4 - X2 - X1 - X3 -

H1 - H4 -

3M0000000

ENCLOSURE TYPE 2 (IP20). RAINPROOF TYPE 3R ENCLOSURE (IP22) WHEN PROVIDED SHIELD 9T18Y1071G06

BEFORE HANDLING, INSTALLING AND OPERATING, SEE INSTRUCTION 475A667AAP001

ALUMINUM CONDUCTOR PRIMARY: 10 KV BIL SECONDARY: 10 KV BIL

IN ACCORDANCE WITH NEC SECTION 450-9, ALLOW AT LEAST SIX INCHES CLEARANCE FOR VENTILATION. CHECK ADDITIONAL NEC AND LOCAL CODES.

ASSEMBLED IN MEXICO

X3 - X1 - X2 X4

- - H4 - H1 - -

Note:

Outline: 303B409CAP074

NEMA CLASS AA DRY TYPE TRANSFORMER

Energy Efficiency in accordance with CSA C802.2-18 and DOE 2016