

# TYPICAL TEST DATA

## LV Dry Type Transformer



**MODEL #: 9T33C2672G15**

**Underwriters Laboratories Inc. Listed**

### RATINGS

KVA	37.5	Conductor	CU
Frequency (Hz)	60	Phase	1
Primary Voltage	240X480 (+1/-2 @5%)	Secondary Voltage	120/240
Current Line Primary (A)	78.10	Current Line Secondary (A)	156.30
Frame	XV173	Insulation System (°C)	220
K Factor	1	Average Sound Level (dB)	45
Temp. Rise (°C)	115	Efficiency standards	CSA 2018 (C802.2-18) & DoE 2016 (10CFR 431)
Electrostatic shield	None		

### LOSS DATA @ 100% LOAD

Core Loss or No Load Loss @ 100% voltage (Watts)	150.8
Impedance Loss or Coil Loss @ Rise + 20 °C reference (Watts)	<u>647.5</u>
Total Loss @ Rise + 20 °C reference (Watts)	798.3

### DIELECTRIC AND PRODUCTION TESTING

Induce Test @ Twice rated voltage 400 Hz per UL1561 and NEMA ST-20  
 Hipot Test for High Voltage winding to Low Voltage and Ground @ 4000 volts 60 Hz, 60 Sec  
 Hipot Test for Low Voltage winding to High Voltage and Ground @ 2500 volts 60 Hz, 60 Sec  
 Polarity additive in accordance with UL1561 and NEMA ST-20

### EFFICIENCY:

CSA 2018 (C802.2-18) efficiency levels

<u>Load (%)</u>	<u>Efficiency (%)</u>
16	97.33
25	98.06
35	98.37
50	98.49
75	98.39
100	98.17

### IMPEDANCE:

Impedance at reference temperature of Rise + 20 °C (Calculated)

%R	1.70
%X	3.00
%Z	3.50
X/R Ratio	1.76

### REGULATION:

Regulation at reference temperature of Rise + 20 °C (Calculated)

<u>Power Factor</u>	<u>Regulation (%)</u>
1	1.70
0.9	2.90
0.8	3.20

### REFERENCE VALUES:

Peak Inrush Current (Calculated)

Imax @8.33 ms (A RMS)≈	2041.4
Imax @ 100 ms (A RMS)≈	876.5