



Transformer

Catalog Number 9T64C9558G03

9Q3C300AABN04A2T00

300.0 KVA 60 HZ 3 PH 2.4 % IMP

40 C AMB. 150 C RISE 220 C SYSTEM IS-19C Type: QL

Note: Design is based on 500.0KVA & 150C Rise 4% Imp.

PRIMARY (H)	480 VOLTS (LINE-LINE)
SECONDARY (X)	415 VOLTS (LINE-LINE)
	240 VOLTS (LINE-NEUTRAL)

ELECTROSTATIC GROUND SHIELD IN EACH PHASE

ENCLOSURE TYPE 2 (IP30). RAINPROOF TYPE 3R ENCLOSURE (IP32) WHEN PROVIDED SHIELD 9T18Y4322G68


SUITABLE FOR NONSINUSOIDAL CURRENT LOAD WITH K-FACTOR NOT TO EXCEED 4
BEFORE HANDLING, INSTALLING AND OPERATING, SEE INSTRUCTION 475A667AAP001
COPPER CONDUCTOR PRIMARY: 10 KV BIL SECONDARY: 10 KV BIL

**IN ACCORDANCE WITH NEC SECTION 450-9, ALLOW AT LEAST SIX INCHES
CLEARANCE FOR VENTILATION. CHECK ADDITIONAL NEC AND LOCAL CODES.**


GE Energy Industrial Solutions

NEMA CLASS AA DRY TYPE TRANSFORMER

Meets TP-1 2002 efficiency



COIL TAP ARRANGEMENT



JUMPER CONNECTION	
TAP	VOLTS
1-2	501
2-3	490
3-4	480
4-5	468
5-6	457
6-7	447
7-8	436

NET WGT 4050 LB 1837.1 Kg

090115 N536! YF379

55808 NOG



LISTED 769G

Outline: 3038919AAP179

Assembled in Mexico

INSPECTION & FINAL TEST

N536!

