

GE Consumer & Industrial

Specialty Transformer PO Box 1701 Ft. Wayne, IN 46801 (260) 439-2000

GE MODEL #: 9T83B3882G03

Underwriters' Laboratories Inc Listed

RATING:

AL 3PH 60HZ 30.0KVA 480 +2,-4(2.5%TAPS) 240

Frame = EE72
Temp. Rise (C) = 150 Insulation System = 220C
Average Sound Level (dB) = 45

LOSS DATA:

Max Core Loss or No Load Loss @ 100% voltage (Watts) =	230.0
Impedance Loss or Coil Loss @ Rise + 20C reference (Watts) =	<u>1,160.2</u>
Total Loss @ Rise + 20C reference (Watts) =	1,390.2

DIELECTRIC AND PRODUCTION TESTING:

Induce Test @ Twice rated voltage 400 Hz per ANSI C89.2 and NEMA ST-20 Hipot Test for High Voltage winding to Low Voltage and Ground @ 4000 volts 60 Hz 60 Sec. Hipot Test for Low Voltage winding to High Voltage and Ground @ 2500 volts 60 Hz 60 Sec. Polarity additive in accordance with ANSI C89.2 and NEMA ST-20

EFFICIENCY:

Efficiencies at reference temperature of Rise + 20C (Calculated).

Load (%) Efficiency (%) at least 97.5

IMPEDANCE:

Impedance at reference temperature of Rise + 20C (Calculated).

%R = 3.8 %X = 4.9 %Z = 6.0

REGULATION:

Regulation at reference temperature of Rise + 20C (Calculated).

PF	Regulation (%
1.0	3.9
0.8	6