



Ref. Certif. No.

CN27964

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE

Product  
Produit

Automatic Transfer Switching Equipment

Name and address of the applicant  
Nom et adresse du demandeur

GE Zenith Controls  
830 W 40th St. Chicago, Illinois, USA

Name and address of the manufacturer  
Nom et adresse du fabricant

GE Zenith Controls  
830 W 40th St. Chicago, Illinois, USA

Name and address of the factory  
Nome et adresse de l'usine

Note: When more than one factory, please report on page 2  
Note: Lorsque plus d'une usinem, veuillez utiliser la 2<sup>me</sup> page

GE Zenith Controls  
830 W 40th St. Chicago, Illinois, USA

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

Ui:690V;Ith=3200A;Ue:AC380V,AC400V,AC415V,AC440V,AC480V;  
Ie:1600A,2000A,2600A,3000A,3200A;AC-32A;Icm(Peak)=105kA;Icw=  
50kA 60ms;Class PC;3P,4P

Trademark (if any)  
Marque de fabrique (si elle existe)

GE

Model / Type Ref.  
Ref. De type

ZTS000B0...,ZTSD00B0...,ZBTS00B1...,ZBTSD0B1...

Additional information (if necessary may also be reported  
on page 2)  
Les informations complémentaires (si nécessaire, peuvent être  
indiqués sur la 2<sup>me</sup> page)

PUBLICATION EDITION

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 60947-6-1:2005(2nd Edition) in conjunction with IEC 60947-1:2004  
(4th Edition)

As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constire partie de ce Certificat

C009-CB2013CQC-050653

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: 2013-09-09

Signature:

Wang Kejiao

Issued 2003-05  
China Quality Certification Centre  
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86-10-83886666  
Fax: +86-10-83886282

website  
www.cqc.com.cn

CB 0021966

ZTS000B0 , ZTSD00B0 , ZBTS00B1 , ZBTSD0B1

**No. 1-5:** Design model: ZTS=ZTS standard series, ZTSD=ZTSD Delay series, ZBTS=ZTS Standard Bypass series, ZBTSD=ZTS Delay bypass series

**No. 6:** Design mode: 0=Null.

**No. 7-8:** Control panel: B0=ZTS Non bypass type, B1=ZTS Bypass type

**No. 9:** Application: 0=Utility- Generator. U=Utility-Utility, M=Manual, G=Generator-Generator.

**No. 10-12:** Ampere size : 160=1600A,200=2000A,260=2600A,300=3000A,320=3200A

**No. 13:** Switched poles: E=3, F=4

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2013-09-09

Signature: \_\_\_\_\_



Wang Kejiao