

CERTIFICATE OF COMPLIANCE

Certificate Number 20131128- E314363
Report Reference E314363-20131127
Issue Date 2013-November-28

Issued to: GE ZENITH CONTROLS,
830 W 40TH ST,
CHICAGO IL 60609.

**This is to certify that
representative samples of**


AUTOMATIC TRANSFER SWITCHES OVER 600 VOLTS
Listed Automatic transfer switches rated more than 600
volts ac for use in emergency systems, Cat No. ZTSMV.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:
Additional Information:

UL 1008A-MEDIUM-VOLTAGE TRANSFER SWITCHES
See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

