


# CERTIFICATE OF SEISMIC COMPLIANCE

For QB, IP and QMS Series Transformers

Qualified to IEEE-693-2005

Qualified to IBC-2006

$S_{ds} = 2.0g$ ,  $S_s = 300\%$ ,  $I_p = 1.5$ , for all z/h  
in accordance with ICC-ES-AC156.



Lowest equipment natural frequency: 22.7 Hz Qualified by shake-table testing, Clark Dynamic Test Laboratory, Jan. 2006

**THIS IS TO CERTIFY THAT THE ABOVE NAMED EQUIPMENT MEETS OR EXCEEDS ALL OF THE ABOVE REQUIREMENTS ACCORDING TO IEEE-693-2005 AND IBC-2006.**

Certification Report Prepared by

**W. E. Gundy & Associates, Inc.**

P.O.Box 2900, Hailey, ID, 83333

See GE document 10095845P1 for Certification Report, interpretation of test data and P.E. stamp.

