

# Certificate of Compliance

Certificate Number 20090822- E23911E  
Report Reference E23911, 1982 November 19  
Issue Date 2009 September 22

Page 1 of 2



*Issued to:* **ZENITH CONTROLS INC**

**830 W 40TH ST  
CHICAGO, IL 60609 USA**

*This is to certify that  
representative samples of*

## **Automatic Transfer Switches for Use in Emergency Systems**

**Model Descriptions Type ZTG, ZTGD, ZTS, ZTSD, or ZTSCT, CTS, CTSD, CTG, CTGD, CTSCT followed by H, K, or L followed by 160, 161, 200 or 201, followed by B, E or F, followed by C, CS, S or X, followed by 1 through 5, 7 through 9, 11 through 59, or 71 through 99, with or without additional suffixes. May include prefix letter K for export.**

*Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* **The basic standards used to investigate products in this category are ANSI/UL 1008, "Transfer Switch Equipment" and CSA-C22.2 No. 178.1-2007, "Requirements for Transfer Switches."**

*Additional Information:* **Ratings:**  
*(Cont.)*

**These devices are suitable for control of motors, electric discharge lamps, tungsten filament lamps and electric heating equipment where the sum of motor full-load ampere ratings and the ampere ratings of other loads do not exceed the ampere rating of the switch and the tungsten load does not exceed 30 percent of the switch rating.**

# Certificate of Compliance



**Underwriters  
Laboratories Inc.®**


*Additional Information:  
(Cont.)*

**Ratings:**

<u>Type</u>	<u>A</u>	<u>Maximum V ac</u>
ZTG/ZTGD/ZTS/ZTSD/ ZTSCT/CTS/CTSD/ CTG/CTGD/CTSCT	1600	480
ZTG/ZTGD/ZTS/ZTSD/ ZTSCT/CTS/CTSD/ CTG/CTGD/CTSCT	2000	480

**Control circuit voltages may be 120 or 208-240 V, depending upon the rating of the power poles.**

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by:

*Jim Larin*

**Jim Larin, Customer Service Specialist**

Underwriters Laboratories Inc.

Reviewed by:

*Jeffrey Hidaka*

**Jeffrey Hidaka, Primary Designated Engineer**

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL

For questions in The United States of America you may call 1-877-UL-HELPS.