
## Determination of Individual Component SCCR UL 508A SB4.2



Compare the SC rating of the lowest rated component with the SC rating of the branch circuit protection device. The smaller of the two ratings is the SC rating for the line side of the PCPD. Proceed to SB4.3

No